

Novatech N.V.
 Industrielaan 5B
 2250 Olen
 Belgium

Test of Radon Transmission

(3 appendices)

The report is revised due to an error in the result table (page 4). The description of the test specimen is changed. Moreover, the information about the client is altered.


The assignment was to determine the radon transmittance through the material. The material was sent to us by the client. The sample arrived at SP (SP Technical Research Institute of Sweden) on 6th August 2012, with no visible damages.

Description of the test material

The tested material (named Tec7, Batchnumber 122315906996, white) was a flexible radon membrane that was casted in a mould by the client. The average thickness is 8.3 mm (measured in 16 locations). A photo of the material is shown in Appendix 1. The material was tested with no joints.

Test equipment

Testing was carried out in a test chamber comprising of two stainless steel boxes. Each box measured 500 x 500 mm. The depth of the receiver box was 104 mm and the depth of the source box was 170 mm. The test sample was placed between the boxes. The sides were then carefully tightened, to ensure an airtight connection between the boxes. A diagram of the test apparatus is presented in Figure 1 below.



The designations C_1 , V etc. are described under Theory.

Figure 1. Test equipment

Radon source

The radon source was a block of aerated concrete which contains a small amount of radium. The radioactive decay of radium will produce radon gas (Rn-222) which is emitted to the atmosphere in the source box. Rn-222 is also radioactive and its first decay product (RnD) is

SP Technical Research Institute of Sweden

Postal address
 SP
 Box 857
 SE-501 15 BORÅS
 Sweden

Office location
 Västeråsen
 Brinellgatan 4
 SE-504 62 BORÅS

Phone / Fax / E-mail
 +46 10 516 50 00
 +46 33 13 55 02
 info@sp.se

This document may not be reproduced other than in full, except with the prior written approval of SP.

Polonium-218. Radon decay products (RnD) are not gases but particles, and cannot pass through the test specimen by diffusion.

Instrumentation

The radon concentration on each side of the test specimen was determined by instruments of type Atmos 33, SP No. 202266, produced by Gammadata in Sweden. The measuring principle used in these instruments is to determine the concentration of Polonium-218 and convert it into radon concentration assuming an invariable relationship between the Rn and Po concentrations.

The instrument was calibrated at the Swedish Radiation Protection Institute on 26th October 2011.

Test room

Testing was carried out in a room with following conditions: a relative humidity of 48.6 - 50.2 %, and a temperature of 23.4-23.8 °C. The ambient air pressure varied between 995 and 1000 hPa. These conditions were continuously monitored throughout the full duration of the test (5 days). The background radon activity in the room was <50 Bq/m³ before and <50 Bq/m³ after the test.

Theory

The emission of radon from the radon source will lead to a build-up of the radon concentration in the source box and a difference in radon concentration between the source and receiver box. This difference will cause a flow of radon by diffusion through the test specimen. Only the radon gas (Rn) and not the radon decay products (RnD) will pass through the test specimen. The radon transmittance is determined by measuring the radon concentration on both sides of the test specimen, as the radon is flowing through the test material.

In evaluating the radon transmission, it is assumed that the radon concentration in both the source and receiver box is increasing linearly with time during a time interval t_1 to t_2 . Radon gas decomposition is considered only in the receiver box.

The density of radon flow through the test specimen is written

$$q = P \cdot (C_1 - C_2) \tag{1}$$

- where q = density of radon flow (Bq/m² · s)
- P = radon transmittance (m/s)
- C_1, C_2 = radon concentration on both sides of the test specimen (Bq/m³)

The differential equation for the radon concentration build-up in the receiver box (C_2) is

$$\frac{dC_2}{dt} = P \cdot (C_1 - C_2) \cdot \frac{A}{V} - \lambda \cdot C_2 \tag{2}$$

- where t = time (s)
- A = test specimen area (m²)
- V = receiver box volume (m³)
- λ = $2.1 \cdot 10^{-6}$ decay constant (s⁻¹)

With $C_1 = a + b \cdot C_2$ equation (2) becomes

$$\frac{dC_2}{(a + b \cdot C_2 - C_2) \cdot \frac{P \cdot A}{V} - \lambda \cdot C_2} = dt \quad (3)$$

or

$$\frac{dC_2}{a + C_2 \cdot \left(b - 1 - \frac{\lambda \cdot V}{P \cdot A} \right)} = \frac{P \cdot A}{V} \cdot dt \quad (4)$$

Integration between t_1 and t_2 and C_2^1 and C_2^2 gives

$$\frac{1}{b - 1 - \frac{\lambda \cdot V}{P \cdot A}} \cdot \ln \left[\frac{a + \left(b - 1 - \frac{\lambda \cdot V}{P \cdot A} \right) \cdot C_2^1}{a + \left(b - 1 - \frac{\lambda \cdot V}{P \cdot A} \right) \cdot C_2^2} \right] = \frac{P \cdot A}{V} \cdot (t_1 - t_2) \quad (5)$$

From equation (5) P is calculated.

Sometimes the radon resistance Z (s/m) rather than the radon transmittance is used

$$Z = \frac{1}{P} \quad (6)$$

For test specimens made of homogenous materials radon permeability can be determined

$$k = \frac{d}{Z} = P \cdot d \quad (7)$$

where k = radon permeability (m²/s)

d = test specimen thickness (m)

The first readings of C_1 and C_2 are taken at the earliest 4 h after the test commenced and further readings are taken once or twice every day.

Calculation and presentation of transmittance/permeability is done as soon as both the C_1 - and C_2 -curves are linear with time. The results are presented for the whole period with linear curves, normally a period of 2-6 days.

Test results

The test commenced on 13th August 2012 and was terminated on 17th August 2012. The results given in the table below are subject to the following conditions: the surface area of the test material is 0.25 m², and the volume of the receiver box is 0.026 m³.

Receiver box, C ₂		Source box, C ₁		Air pressure ¹ , hPa
Radon concentration, Bq/m ³	Time, s	Radon concentration, Bq/m ³	Time, s	
21	17400	2712	24600	995
36	89400	10090	105000	1000
188	178200	17114	199200	999
402	264600	12651	286800	997
634	348000	24132	357600	998

The radon transmittance of the material is calculated to

$$P = 2.0 \cdot 10^{-8} \text{ m/s}$$

and the radon permeability (measured thickness of test specimen 0.0083 m) to

$$k = 1.6 \cdot 10^{-10} \text{ m}^2/\text{s}$$

Measurement uncertainty

The expanded uncertainty of the measurement is estimated to ±21 %, including coverage factor k = 2. The uncertainty of temperature is ±2 °C and of relative humidity ±5 % in the test room.

Comments

The test results are only valid for the tested specimen

**SP Technical Research Institute of Sweden
Energy Technology - Building Physics and Indoor Environment**

Performed by

Examined by



Henrik Karlsson



Eva-Lotta Kurkinen

Appendices

Photograph of test sample

Photograph of test equipment

An example of calculation of indoor radon concentration in a building with ground radon barrier

¹ Recorded in connection with the reading of the radon concentration in the receiver box.

Appendix 1


Photograph of test sample



Test specimen

Appendix 2

Photograph of test equipment



Appendix 3

An example calculation of indoor radon concentration in a building with a ground radon barrier

The following calculation assumes that there are **no** radon-emitting materials in the structure of the building.

Given

Room volume $V = 29 \text{ m}^3$

Surface area $A = 12 \text{ m}^2$ (to the ground)

Radon concentration in the ground $C_g = 50\,000 \text{ Bq/m}^3$

Ventilation air change rate in the room $n = 0.5$ air changes/h

Calculation

The radon flow, q , from the ground to the building is given by

$$q = P \cdot (C_g - C_i) \quad \text{Bq/m}^2\text{s}$$

where P = the radon transmittance

C_i = the indoor radon concentration

For the test specimen, P is calculated to $2.0 \cdot 10^{-8} \text{ m/s}$ (see test report).

Assuming that C_i is small compared to C_g this gives a radon flow rate $q = 0.001 \text{ Bq/m}^2\text{s}$.

The indoor radon concentration, C_i , can be expressed as the outdoor concentration, C_e , plus the quantity of radon emitted to the indoor air from the ground.

The indoor radon concentration:

$$C_i = C_e + \frac{q \cdot A \cdot 3600}{n \cdot V}$$

This gives an indoor radon concentration of about 3.0 Bq/m^3 , plus the outdoor radon concentration (C_e). The same calculation as above, except for an air change rate of 0.1 air changes/h, gives an indoor radon concentration of about 14.8 Bq/m^3 , plus the outdoor radon concentration (C_e).

Note

This type of calculation can be used for barriers applicable to protect against ground radon. It assumes that joints, inlets and connections are radon tight. The value of P in the calculation above, is valid for the material with no joints.

Email from Henrik Karlson 27.08.2012:

The question about the interpretation of the test result is actually not the responsibility of SP Technical Research Institute of Sweden. It depends on the use of the product and the regulations in the specific country and the use of the specific building or building component. For instance, the Swedish building regulation state that the indoor concentration of radon must not exceed 200 Bq/m^3 (yearly average).

Swedish building regulation does not mention any method how to fulfill this limit or what properties a radon membrane product must fulfill. Moreover, in Norway you can certify (SINTEF technical approval) a "radon membrane" (<http://www.sintefcertification.no/en-us/Drilldown.aspx?sectionId=11&portalMenuId=69&nodeId=1489&level=1&isLast=True>).

The radon transmittance must be lower than $2 \times 10^{-8} \text{ m/s}$ in order to fulfill the regulations of the SINTEF technical approval.

Hence, the Tec7 product is sufficiently radon tight to fulfill the SINTEF technical approval.

You can also see the simplified calculation in appendix 3 in the report.